

CONFORMITY EXAMINATION CERTIFICATE

Issued by Aboma Inspections bv

Certificate no.:
202302234

Description of the product:

Adjustable telescopic steel prop in compliance with "EN1065 – Adjustable telescopic steel props- product specifications, design and assessment by calculations and tests"

Trademark and type:

BM Schroefstempel

Name and address of the manufacturer:

Orion Metal BV
Industrieweg 4
3950 Bochoft
Belgium

Name and address of the certificate holder:

Scafom Holding BV
Postbus 2119
6020 AC Budel
The Netherlands

Applicable EC-Directives:

Not Applicable

Certificate based on (parts) of the (harmonised) standard(s):

EN1065 – Adjustable telescopic steel props- product specifications, design and assessment by calculations and tests

Date of conformity examination:

11-14-2023 til 11-30-2023

Documents and reports belonging tot his certificate:

Report: 202302234JMB02Rev0 Rapport conformiteitsbeoordeling and digital conformity examination file project number: 202302234

Additional remarks:

Models BM450 and BM540 fully comply with the specified standard in terms of design and mechanical strength, except that the length is not specified by the standard. They are therefore not provided with the required marking "EN1065"

Conclusion:

The machine and technical file meet the requirements of the relevant demands of the standard EN1065, taking into account the remarks mentioned in this certificate.

Date : 30-11-2023
Valid until : 30-11-2028

ing. B.C.M. van Gruijthuijsen
General Manager

J.M.W. Boeijen
Senior Inspecteur
Onderzoeker

Ede



Report conformity examination

Report belonging to conformity examination belonging to his certificate:

202302234JMB02Rev0 Rapport conformiteitsbeoordeling

Date Report:

06-12-2019

09-12-2020

16-11-2023

Date of issue of original certificate:

06-12-2019

Project number Aboma Inspections bv:

202302234

Examination carried out by:

J.M.W. Boeijen

Senior Inspecteur


Aboma Inspections bv

Description of the machine

BM-Schroefstempel according EN1065. The type includes the following models.			
-	BM250	-	BM400
-	BM300	-	BM450
-	BM350	-	BM540

Type:	Gewicht (kg)	ingeschoven	uitgeschoven
BM 250	14,7	1,53 m	2,50 m
BM 300	15,9	1,78 m	3,00 m
BM 350	18,2	2,03 m	3,50 m
BM 400	19,3	2,28 m	4,00 m
BM450	21,6	2,51 m	4,48 m
BM540	25,0	3,01 m	5,38 m

Let op: Stempels met een gewicht >23 kg mogen niet door 1 persoon gehandeld worden!



CODERING(*):
EN1065-A-BMXXX-XX
PRODJAAR

(*) : Alleen voor BM250 t/m 400
Codring voor BM450 en BM540:
BMXXX-XX
PRODJAAR
TYPE

(*) : Alleen voor BM250 t/m 400
Codring voor BM450 en BM540:
BMXXX-XX
PRODJAAR
TYPE

CODERING(*):
EN1065-A-BMXXX-XX
PRODJAAR

Examinations and tests

202302234JMB01Rev0 rapport Scafom BM stempels

Results

Examination:

No deviances were found that would not make prolongation of the declaration possible. The investigation has been concluded with positive results.

Technical file:

Based on the content of the technical file, it can be concluded that the product has remained unchanged.

Calculations:

Considered not applicable due to prolongation of the certificate

CE-marking and EC-declaration:

Nor applicable.

Conclusion

Based upon the results of the conformity examination Aboma Inspections bv issues a prolongation of the conformity examination certificate.

The conformity examination certificate is only valid for products which are in conformity with the same specifications as the type certified product.

The certificate is issued based on the requirements that are valid at the date of issue.

Disclaimer

In case of changes of the product specifications, changes in the requirements or changes in the state of the art the certificate holder shall request Aboma Inspections bv to reconsider the validity of the certificate.

The manufacturer requests Aboma Inspections bv to reconsider the validity of the certificate every five years.

Annexes

202302234JMB02Rev0 Rapport conformiteitsbeoordeling
202302234JMB01Rev0 rapport Scafom BM stempels